

## **SEWER LINE REPAIR ON 5<sup>TH</sup> STREET 1/18/2015**

10:00am- Dug up the sewer line and discovered that 13 feet of sewer line was broke and shifted all the way to manhole between alley ways on 5<sup>th</sup> street hill.

12:00am- Called in an emergency parts order to first supply for a 14ft 8 inch piece of pvc sewer pipe and a fernco from concrete pipe to pvc.

1:30pm- Returned back with parts, cut old pipe off and chipped old concrete pipe out of manhole. Put new sand for base under pipe and compacted it.

2:30pm- Installed fernco and new section of pipe. We then mortared the joint at the manhole.

3:30pm- Tim Davison hauled in 4 loads of clean sand and backfilled the sewer line.

5:30pm- Tim Davison hauled in 2 loads of rock to finish backfilling the last 1foot of the hole.

6:00pm- We cleaned up the work area and reopened 5<sup>th</sup> street to traffic.